



Purchasing Services Office  
801 Leroy Place  
Socorro, NM 87801  
(575) 835-5881

Letter of Addendum

TO: All Offerors

FROM: Kimela Miller

DATE: December 10, 2021

RE: RFP Number: 2211026P – Amendment #3  
Commodity: Playas Pre-Engineered Steel Warehouse

Please check the NM Tech website often for updates on this RFP.

Q1) Are standard PEMB walk doors acceptable? If so, what hardware is required?

A1) Yes. The type of hardware will be decided at a later date.

Q2) Collateral load is not specified. Will this building have a fire protection sprinkler system due to larger than 12,000sf? 3psf for sprinkler, 1psf for electrical, 1psf for mechanical for a total of 5psf?

A2) Yes.

Q3) Are gutters and downspouts required?

A3) Yes.

The RFP due date is changed from 12/14 to 12/16 at 2:00 pm local time.

All Offerors are required to confirm the receipt of this amendment in their response. All other terms and conditions of the RFP remain unchanged.

Xc: File